


Sheet 1



Job #: Sample2 Customer
Performed by rick for:

Sample2 customer
Fitzhugh
Austin, TX

Rick's Heating & AC

Box 204433
Austin, TX 78720
Phone: 512-258-4748

Scale: 1/8" = 1'0"

Page 1
Right-Suite Residential J8
5.8.48 RSR30501
2003-Aug-23 08:57:53

D:\datarick\Wrightsoft HVAC\sample...

Project Information

For: Sample2 customer
Fitzhugh, Austin, TX

Design Conditions

Location:

Austin, TX, US
Elevation: 620 ft
Latitude: 30°N

Outdoor:

	Heating	Cooling
Dry bulb (°F)	25	98
Daily range (°F)	-	20 (M)
Wet bulb (°F)	-	74
Wind speed (mph)	15.0	7.5

Indoor:


	Heating	Cooling
Indoor temperature (°F)	70	75
Design TD (°F)	45	23
Relative humidity (%)	30	50
Moisture difference (gr/lb)	17.8	24.9

Infiltration:

Method	Simplified
Construction quality	Tight
Fireplaces	1 (Average)


Heating

Component	Btuh/ft²	Btuh	% of load
Walls	2.9	9708	17.8
Windows	21.2	4583	8.4
Doors	17.5	1106	2.0
Ceilings	1.8	5059	9.3
Floors	5.3	13859	25.4
Infiltration	3.3	11954	21.9
Ducts		3835	7.0
Piping		0	0.0
Humidification		0	0.0
Ventilation		4483	8.2
Total		54585	100.0



Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	1.6	5282	17.6
Windows	23.8	5142	17.2
Doors	13.6	854	2.9
Ceilings	2.1	5704	19.0
Floors	0.0	0	0.0
Infiltration	0.9	3095	10.3
Ducts		3040	10.1
Ventilation		2321	7.7
Internal gains		4520	15.1
Blower		0	0.0
Total		29958	100.0



Overall U-value = 0.088 Btuh/ft²·°F

Project Information


For: Sample2 customer
 Fitzhugh, Austin, TX

Design Conditions

Location:		Indoor:		Heating	Cooling
Austin, TX, US		Indoor temperature (°F)		70	75
Elevation:	620 ft	Design TD (°F)		45	23
Latitude:	30°N	Relative humidity (%)		30	50
Outdoor:		Moisture difference (gr/lb)		17.8	24.9
		Heating	Cooling		
Dry bulb (°F)		25	98		
Daily range (°F)		-	20 (M)		
Wet bulb (°F)		-	74		
Wind speed (mph)		15.0	7.5		
		Infiltration:			
		Method		Simplified	
		Construction quality		Tight	
		Fireplaces		1 (Average)	

Test for Adequate Exposure Diversity

Hourly Glazing Load



Maximum hourly glazing load exceeds average by 25.1%.

House has adequate exposure diversity (AED), based on AED limit of 30%.

Recommended procedure: Average

Selected procedure: Average (auto)



Project Summary
Entire House
Rick's Heating & AC

Job: Sample2 Customer
 Date: 6/15/03
 By: rick

Box 204433, Austin, TX 78720 Phone: 512-258-4748 Email: austintexasrick@yahoo.com Web: www.ricksair.com

Project Information

For: Sample2 customer
 Fitzhugh, Austin, TX

Notes: Quality Service saves you \$\$\$

Design Information

Weather: Austin, TX, US

Winter Design Conditions

Outside db 25 °F
 Inside db 70 °F
 Design TD 45 °F

Summer Design Conditions

Outside db 98 °F
 Inside db 75 °F
 Design TD 23 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 25 gr/lb

Heating Summary

Building heat loss 50102 Btuh
 Ventilation air 93 cfm
 Ventilation air loss 4483 Btuh
 Design heat load 54585 Btuh

Infiltration

Method Simplified
 Construction quality Tight
 Fireplaces 1 (Average)

	Heating	Cooling
Area (ft²)	2611	2611
Volume (ft³)	37046	37046
Air changes/hour	0.40	0.20
Equiv. AVF (cfm)	247	123

Heating Equipment Summary

Make n/a
 Trade
 Model n/a

Efficiency 100 EFF
 Heating input 0 Btuh
 Heating output 54585 Btuh
 Temperature rise 38 °F
 Actual air flow 1350 cfm
 Air flow factor 0.027 cfm/Btuh
 Static pressure 0.80 in H2O
 Space thermostat

Sensible Cooling Equipment Load Sizing

Structure 27637 Btuh
 Ventilation 2321 Btuh
 Design temperature swing 3.0 °F
 Use mfg. data n
 Rate/swing multiplier 1.03
 Total sens. equip. load 30946 Btuh

Latent Cooling Equipment Load Sizing

Internal gains 800 Btuh
 Ventilation 1531 Btuh
 Infiltration 2042 Btuh
 Total latent equip. load 4768 Btuh

Total equipment load 35714 Btuh
 Req. total capacity at 0.70 SHR 3.7 ton

Cooling Equipment Summary

Make Goodman Mfg.
 Trade Janitrol, GMC, Franklin
 Cond CKJ42-1D
 Coil AR49-1

Efficiency 12 SEER
 Sensible cooling 28350 Btuh
 Latent cooling 12150 Btuh
 Total cooling 40500 Btuh
 Actual air flow 1350 cfm
 Air flow factor 0.049 cfm/Btuh
 Static pressure 0.80 in H2O
 Load sensible heat ratio 86 %

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.



Short Form
Entire House
Rick's Heating & AC

Job: Sample2 Customer
 Date: 6/15/03
 By: rick

Box 204433, Austin, TX 78720 Phone: 512-258-4748 Email: austintexasrick@yahoo.com Web: www.ricksair.com

Project Information

For: Sample2 customer
 Fitzhugh, Austin, TX

Design Information

	Htg	Clg		Infiltration
Outside db (°F)	25	98	Method	Simplified
Inside db (°F)	70	75	Construction quality	Tight
Design TD (°F)	45	23	Fireplaces	1 (Average)
Daily range	-	M		
Inside humidity (%)	-	50		
Moisture difference (gr/lb)	-	25		

HEATING EQUIPMENT

Make n/a
 Trade
 Model n/a

Efficiency 100 EFF
 Heating input 0 Btuh
 Heating output 54585 Btuh
 Temperature rise 38 °F
 Actual air flow 1350 cfm
 Air flow factor 0.027 cfm/Btuh
 Static pressure 0.80 in H2O
 Space thermostat

COOLING EQUIPMENT

Make Goodman Mfg.
 Trade Janitrol, GMC, Franklin
 Cond CKJ42-1D
 Coil AR49-1

Efficiency 12 SEER
 Sensible cooling 28350 Btuh
 Latent cooling 12150 Btuh
 Total cooling 40500 Btuh
 Actual air flow 1350 cfm
 Air flow factor 0.049 cfm/Btuh
 Static pressure 0.80 in H2O
 Load sensible heat ratio 86 %

ROOM NAME		Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Eastsidezone (Rest of House)	p	882	25142	17633	677	861
	d	1729	24961	12427	673	607
Entire House	d	2611	50102	27637	1350	1350
Ventilation air			4483	2321		
Equip. @ 1.03 RSM				30946		
Latent cooling				4768		
TOTALS		2611	54585	35714	1350	1350

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.



Operating Cost Summary
Entire House
Rick's Heating & AC

Job: Sample2 Customer
 Date: 6/15/03
 By: rick

Box 204433, Austin, TX 78720 Phone: 512-258-4748 Email: austinTEXASrick@yahoo.com Web: www.ricksair.com

Project Information

For: Sample2 customer
 Fitzhugh, Austin, TX

Notes: Quality Service saves you \$\$\$

System Annual Fuel Cost Comparison

	Base System	Investment 1	Investment 2	Investment 3
System Name:	AC	ASHP	ASHP	ASHP
Cooling \$:	797.37	656.24	650.85	749.19
Heating \$:	1757.56	587.85	573.01	620.41
Hot Water \$:	0.00	0.00	0.00	0.00
Total \$:	2554.93	1244.09	1223.86	1369.61

Long-term Operating Cost Comparison

REFERENCE

	Cost	Savings	Cost	Savings	Cost	Savings	Cost	Savings
Year 1 \$:	2555	0	1244	1311	1224	1331	1370	1185
Year 2 \$:	5110	0	2488	2622	2448	2662	2739	2371
Year 3 \$:	7665	0	3732	3933	3672	3993	4109	3556
Year 4 \$:	10220	0	4976	5243	4895	5324	5478	4741
Year 5 \$:	12775	0	6220	6554	6119	6655	6848	5927
Year 10 \$:	25549	0	12441	13108	12239	13311	13696	11853
Payback: yrs	0.0		0.8		0.5		1.1	
ROI: %	0.0		29.3		34.2		24.7	
Savings: \$/mo	0.00		109.24		110.92		98.78	

Note: Actual costs and savings may differ due to weather, operating conditions, maintenance, and construction.



Duct System Summary

Entire House

Rick's Heating & AC

Job: Sample2 Customer
 Date: 6/15/03
 By: rick

Box 204433, Austin, TX 78720 Phone: 512-258-4748 Email: austinTEXASrick@yahoo.com Web: www.ricksair.com

Project Information

For: Sample2 customer
 Fitzhugh, Austin, TX

	Heating	Cooling
External static pressure	0.80 in H2O	0.80 in H2O
Pressure losses	0.41 in H2O	0.41 in H2O
Available static pressure	0.39 in H2O	0.39 in H2O
Supply / return available pressure	0.19 / 0.19 in H2O	0.19 / 0.19 in H2O
Lowest friction rate	0.132 in/100ft	0.132 in/100ft
Actual air flow	1350 cfm	1350 cfm
Total effective length (TEL)	296 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	Rect Size (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk	
Livingrm-A	c	5472	219	267	0.236	8	0x0	VIFx	35.4	130.0	st2
Livingrm	c	5472	219	267	0.236	8	0x0	VIFx	35.4	130.0	st2
Bedrm3/office-A	c	4218	84	206	0.233	7	0x0	VIFx	37.2	130.0	st2
Bedrm2/exerrm	h	5763	155	121	0.221	7	0x0	VIFx	46.7	130.0	st2
Hall	h	4039	109	89	0.252	6	0x0	VIFx	24.9	130.0	st1
Hall-A	h	4039	109	89	0.132	7	0x0	VIFx	35.8	260.0	st2
bath2	c	166	3	8	0.249	4	0x0	VIFx	26.4	130.0	st1
MasterBdrm	h	7202	194	149	0.238	7	0x0	VIFx	33.8	130.0	st1
Masterbath	h	2281	61	46	0.259	5	0x0	VIFx	20.7	130.0	st1
Dining	c	1353	61	66	0.269	5	0x0	VIFx	15.1	130.0	st1
util/pantry	c	2914	127	142	0.278	6	0x0	VIFx	10.3	130.0	st1
kitchen	c	351	8	17	0.269	4	0x0	VIFx	15.1	130.0	st1

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	Rect Duct Size (in)	Duct Material	Trunk
st1	Peak AVF	564	518	0.238	718	12	0 x 0	VinIFlx	
st2	Peak AVF	786	951	0.132	889	14	0 x 0	VinIFlx	

Bold/italic values have been manually overridden